

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-1496:121

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Model F600-350 photoelectric type smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector for use with listee's Models F600-MB-6, F600-MB-6LP, F600-MB-6RLY, F600-MB-6RLED or F600-MB-6GLED (CSFM Listing No. 7300-1496:128) mounting base and separately listed compatible fire alarm control units.

XLF: 7272-1394:100

02-19-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager